

From: [Michael Lesser](#)
To: rnovak@pierceatwood.com; ["Todd S. MacDowell"](#)
Cc: ["jeanne.guthrie@sherbornma.org"](mailto:jeanne.guthrie@sherbornma.org)
Subject: Coolidge Crossing revised site lighting plan
Date: Wednesday, April 14, 2021 11:34:00 AM

TO: Sherborn Zoning Board of Appeals

FROM: Michael Lesser
resident: 54 Forest Street, Sherborn

DATE: April 13, 2021

RE: **Comments on Revised Coolidge Crossing Site Lighting Plan as per Hawk Design Inc. April 7, 2021 letter and the Site Lighting Plan rev. 3/31/21**

I want to thank Baystone Development and Hawk Design Inc. for their revised lighting work as it addresses my major concerns of efficiency (130 LPW), wattage (40W) and color (3000K). The changes will significantly lessen the energy use for exterior lighting and are better for health.

As to dimmers and motion sensors, the use of smaller 40W fixtures does greatly reduce the possible energy savings; and the concern for resident safety is recognized.