

§ 305-2.8. Pump houses.

Pump houses and pump rooms shall be installed in accordance with the current version of USEPA's Manual of Individual and Nonpublic Water Supply Systems. Pitless adapters or pitless units shall be installed in accordance with the current version of the National Sanitation Foundation's standard for pitless well adapters.

§ 305-2.9. Pump house protection.

Pump houses, pump or pipe pits and wells shall be designed and constructed so as to prevent flooding, freezing and the entrance of sources of pollution or contamination.